

certificate
no. **IFA 2004051**
dated 2020-02-20

Translation In any case, the German original shall prevail.

DGUV Test Certificate

Name and address of the holder of the certificate (customer): **AMAG Rolling GmbH**
Lamprechthausenerstraße 61
5282 Braunau-Ranshofen
AUSTRIA

Product designation: **Aluminum tread plate with raised pattern according to EN 573-3 and EN 1386**

Type: **AMAG diamond**

Testing based on: **Testing of floor coverings – Determination of the anti-slip property according to DIN 51130 (02.2014) and ASR A1.5/1,2**

Test report: **Test Certificate No. 2020 20572/3210 dated 2020-02-20**
- IFA, Sankt Augustin

Further details: **Intended purpose:**
Floor covering for use in working areas presenting a risk of slipping, for which floor coverings of slip resistance assessment group R10/V6 are specified.

Remarks:
The DGUV test mark may be used only in conjunction with indication of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is entitled to affix the DGUV Test mark shown overleaf to the products complying with the type tested, including the specification given under the heading further details.
The present certificate including the right to affix the DGUV Test mark is valid until: **2025-02-19**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.


Dr. rer. nat. Peter Paszkiewicz
Head of testing and certification body


Dipl.-Ing. Olaf Mewes
Certification Officer

DGUV Test mark

