

certificate

no. IFA 2204112

dated 2022-11-08



IFA

Institut für Arbeitsschutz der
Deutschen Gesetzlichen Unfallversicherung
Prüf- und Zertifizierungsstelle im DGUV Test

Translation In any case, the German original shall prevail.

DGUV Test Certificate

Name and address of the holder of the certificate (customer): AMAG rolling GmbH
Lamprechtshausenerstraße 61
5282 Braunau-Ranshofen
AUSTRIA

Product designation: **Aluminum tread plate with raised pattern**

Type: AMAG duet tear plate, rolled

Testing based on: DIN EN 16165:2021-12 annex B;
Determination of slip resistance of pedestrian surfaces
- Shod ramp test

ASR A1.5/1.2; Technical rules for workplaces – floorings;
Edition: March 2022

E DIN 51133:2021-12; Testing of floor coverings
- Determination of the displacement space


Test report: No.: 2022 22893/3210 dated 2022-11-07
- IFA Sankt Augustin

Further details: Intended purpose:
Floor covering for use in working areas presenting a risk of slipping, for which floor coverings of slip resistance assessment group R10/V10 are specified.

Remarks:
The DGUV test mark may be used only in conjunction with indication of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is entitled to affix the DGUV Test mark shown overleaf to the products complying with the type tested, including the specification given under the heading further details.
The present certificate including the right to affix the DGUV Test mark is valid until: **2027-11-07**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.


Dr. rer. nat. Peter Paszkiewicz
Head of testing and certification body


Dipl.-Ing. Olaf Mewes
Certification Officer

DGUV Test mark



certificate
no. IFA 2204113
dated 2022-11-08

Translation In any case, the German original shall prevail.

DGUV Test Certificate

Name and address of the holder of the certificate (customer): AMAG rolling GmbH
Lamprechtshausenerstraße 61
5282 Braunau-Ranshofen
AUSTRIA

Product designation: **Aluminum tread plate with raised pattern**

Type: AMAG duet tear plate, rolled and pickled

Testing based on: DIN EN 16165:2021-12 annex B;
Determination of slip resistance of pedestrian surfaces
- Shod ramp test

ASR A1.5/1.2; Technical rules for workplaces – floorings;
Edition: March 2022

E DIN 51133:2021-12; Testing of floor coverings
- Determination of the displacement space

Test report: No.: 2022 22894/3210 dated 2022-11-07
- IFA Sankt Augustin

Further details: Intended purpose:
Floor covering for use in working areas presenting a risk of slipping, for which floor coverings of slip resistance assessment group R10/V10 are specified.

Remarks:
The DGUV test mark may be used only in conjunction with indication of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is entitled to affix the DGUV Test mark shown overleaf to the products complying with the type tested, including the specification given under the heading further details.

The present certificate including the right to affix the DGUV Test mark is valid until: **2027-11-07**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.



Dr. rer. nat. Peter Paszkiewicz
Head of testing and certification body



Dipl.-Ing. Olaf Mewes
Certification Officer

DGUV Test mark



certificate
no. **IFA 2204115**
dated 2022-11-08

Translation In any case, the German original shall prevail.

DGUV Test Certificate

Name and address of the holder of the certificate (customer): **AMAG rolling GmbH**
Lamprechtshausenerstraße 61
5282 Braunau-Ranshofen
AUSTRIA

Product designation: **Aluminum tread plate with raised pattern**

Type: **AMAG quintet tear plate, rolled and pickled**

Testing based on: **DIN EN 16165:2021-12 annex B;**
Determination of slip resistance of pedestrian surfaces
- Shod ramp test

ASR A1.5/1.2; Technical rules for workplaces – floorings;
Edition: March 2022

E DIN 51133:2021-12; Testing of floor coverings
- Determination of the displacement space


Test report: **No.: 2022 22896/3210 dated 2022-11-07**
- IFA Sankt Augustin

Further details: **Intended purpose:**
Floor covering for use in working areas presenting a risk of slipping, for which floor coverings of slip resistance assessment group R11/V8 are specified.

Remarks:
The DGUV test mark may be used only in conjunction with indication of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is entitled to affix the DGUV Test mark shown overleaf to the products complying with the type tested, including the specification given under the heading further details.
The present certificate including the right to affix the DGUV Test mark is valid until: **2027-11-07**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.


Dr. rer. nat. Peter Paszkiewicz
Head of testing and certification body


Dipl.-Ing. Olaf Mewes
Certification Officer

DGUV Test mark

